

**BELLA VISTA WATER DISTRICT**  
**APPROVED BACKFLOW ASSEMBLIES**

**3/4" - 2"**

Wilkins 975XL2 series

Febco LF825Y and LF860 series

Watts/Ames LF009 and LF919 series

**2 1/2" And Larger**

Wilkins 375 and 475 series

Febco LF860 and 880 series

**DEDICATED FIRE SUPPRESSION SYSTEMS\***

Wilkins 375 ADA and 475 DA series

Watts 957 RPDA-FS series

Ames C-500 series

Febco LF866 RPDA and LF886 RPDA

\*Dedicated fire suppression systems require a Reduced Pressure Principle Detector Assembly (RPDA). This assembly must be equipped with a meter and endpoint that is compatible with the District's meter reading system as follows: Badger Recordall® Cold Water Bronze Disc Meter with a District approved register and endpoint. The customer is required to purchase the register and endpoint from the District to avoid incompatibility issues. If the assembly does not already include a Badger Recordall® Cold Water Bronze Disc Meter, the meter must also be purchased from the District in addition to the meter register and endpoint.